

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1209:174 Page 1 of 1

CATEGORY: Fire Alarm Devices for Hearing Impaired

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models S1215, S2415, S2475, S2430, S2460, S2495, S24110, S121575 and S241575 strobe lights. Model number may be followed by suffix -W indicating color white, and/or suffix -F, -AG, -P or -EV. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

Electrical:	-12:	10.5 - 17 VDC
	-24:	20 - 30 VDC
Candela:	-15:	15cd
	-1575:	15cd, 75cd on axis
	-30:	30cd
	-60:	60cd
	-75:	75cd
	-95:	95cd
	-110:	110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control unit. For **wall mount** and **indoor** use only.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager